



1 THIS FOUNTAIN REQUIRES THE USE OF MODEL 6521FR FREEZE RESISTANT VALVE ASSEMBLY (SOLD SEPARATELY)

2 VALVE ASSEMBLY MUST BE INSTALLED IN A WARM AREA. PROVISIONS SHOULD BE MADE TO ALLOW ACCESS TO ACCESS PANEL

3. HOLD ROUGH-IN DIMENSIONS ± 1/4" (6.4mm).

4. \* WHEN INSTALLING THIS UNIT LOCAL, STATE OR FEDERAL CODES SHOULD BE ADHERED TO. FOR INSTALLATION HEIGHTS OTHER THAN SHOWN, DIMENSIONS MARKED (\*) MUST BE ADJUSTED ACCORDINGLY.



1455 KLEPPE LANE  
SPARKS, NEVADA 89431  
(775) 359-4712 FAX (775) 359-7424  
E-MAIL: HAWS@HAWS.CO.COM  
WEBSITE: WWW.HAWS.CO.COM

ECN NO. REVISED PER BY:	FV	MODEL(S)	PART NUMBER
ECN: 5013	FV	1109FR/1109FRBP	0002076626.D
DRAWN: FV	DATE: 06/98	CHKD:	DRAWING NO. A
APPROVED: FV	DATE: 07/21/15	SCALE: 1:16	REV 12
DRAWING TYPE: INSTALLATION		SIZE: A	SHEET 1 OF 1