


MOUNTING DETAIL



BURY DEPTHS OF 48" [1219mm] AND 72" [1829mm]. WASTE TO BE 1 1/2" IPS MINIMUM TO A POROUS GRAVEL FILL OR MAIN SEWER LINE LOCATED BELOW FROST LINE (NOT SUPPLIED).

NOTES:

1. -REMOVED-
2. SPACER IS GLUED TO WALL OF PEDESTAL, BUT MAY BE KNOCKED OFF DURING WASTE ARM ASSEMBLY REMOVAL/REPAIR. ENSURE THAT SPACER IS REPLACED TO KEEP HOSE AND WASTE ARM ALIGNED PROPERLY.



1455 KLEPPE LANE
 SPARKS, NEVADA 89431
 (775) 359-4712 FAX (775) 359-7424
 E-MAIL: HAWS@HAWS.CO.COM
 WEBSITE: WWW.HAWS.CO.COM

CON. NO.	REVISED PER:	MODEL(S)	PART NUMBER
DRAWN:	CON. 4635		0002077325.D
DATE:	JDM		REVISION
HM	12/01/95		10
DATE:	VWC		
APPROVED:	DATE:	SCALE:	INSTALLATION
FV	04/21/15	1:1	SIZE: A SHEET 1 OF 1
		DRAWING TYPE:	
			3177FR