



NOTES:

1. THE ANSI Z358.1-2009 STANDARD SPECIFIES EYEWASH NOZZLE HEIGHTS TO BE 83.8cm (33 IN.) TO 114.3cm (45 IN.) ABOVE THE FLOOR. CENTERLINE OF EYEWASH HEADS MUST BE 15.2cm (6 IN.) MIN. AWAY FROM WALL OR NEAREST OBSTRUCTION.
2. DIMENSIONS MAY VARY ±1/2" [13mm].

| | | | | |
|---|--|--|---|--|
|  | | | 1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 E-MAIL: HAWS@HAWSO.COM WEBSITE: WWW.HAWSO.COM | |
| | | | ECN NO. ECN: 5005 DRAWN: C HAYES APPROVED: FV | REVISED PER: HM DATE: 3/19/92 DATE: 06/25/15 |
| SCALE: 1:1 | | | DRAWING TYPE: INSTALLATION | SIZE: A SHEET 1 OF 1 |