


NOTES:

1. WHEN INSTALLING THIS UNIT, LOCAL, STATE OR FEDERAL CODES SHOULD BE ADHERED TO. WASTE CONNECTION MUST ADHERE TO LOCAL HEALTH AND PLUMBING CODES.
2. FLOW RATE FOR EYE/FACE WASH IS 3.7 GPM AND EXCEEDS ANSI STANDARD Z358.1.
3. DIMENSIONS MAY VARY BY $\pm 1/2"$ [12.7mm].
- *4. MOUNTING HARDWARE NOT SUPPLIED.

		1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 E-MAIL: HAWS@HAWS.CO.COM WEBSITE: WWW.HAWS.CO.COM	
		ECN NO. 4290 DRAWN: IR APPROVED:	REVISED PER: BY: IR ECN: 4572 DATE: 8/4/10 DATE:
SCALE: 1:12		DRAWING TYPE: INSTALLATION	
SIZE: A		SHEET 1 OF 1	