



NOTES:

1. TO COMPLY WITH ANSI Z358.1-2009 FOR EMERGENCY EYEWASH OR EYE/FACE WASH AND SHOWER EQUIPMENT:
 - UNIT SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS AND ACCEPTABLE PLUMBING PRACTICES.
 - EYEWASH OR EYE/FACE WASH SHALL BE POSITIONED WITH NOZZLES NOT LESS THEN 83.8 CM (33 IN.) AND NO GREATER THAN 114.3 CM (45 IN.) FROM SURFACE ON WHICH USER STANDS AND 15.3 CM (6 IN.) MINIMUM FROM WALL OR NEAREST OBSTRUCTION.
2. DIMENSIONS MAY VARY ±1/2" [12.7mm].
3. MOUNTING HARDWARE SUPPLIED BY OTHERS.

		1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 E-MAIL: HAWS@HAWS.CO.COM WEBSITE: WWW.HAWS.CO.COM		
		ECN NO. REVISED PER BY: ECN: 4639 IR	MODEL(S) 7778B	PART NUMBER: 0002080103.D
DRAWN: C.J.L.	DATE: 09/91	CHK'D:	DRAWING NO.: 09406A00	REV: 13
APPROVED:	DATE:	EYE/FACE WASH		SCALE: 1/7
DRAWING TYPE: INSTALLATION			SIZE: A	SHEET 1 OF 1